

ADDENDUM # 1

SOUTH BROWARD DRAINAGE DISTRICT

FABRIC FORMED EROSION PROTECTION PROJECT IN MIRAMAR

DATE OF ADDENDUM: December 1, 2014

TO ALL PROSPECTIVE BIDDERS:

PLEASE NOTE THE FOLLOWING CHANGES:

- 1) The crushed lime rock specified in the ITEM NOTES (SECTION 080) on page 080-1 of the bid documents has been changed as follows: crushed lime rock material is not required. The fill/embankment material shall meet a minimum LBR of 40. SBDD shall make a field determination on the suitability of the material. Any required material testing shall be paid for by SBDD and the Contractor shall be responsible to reimburse SBDD for the cost of any failed tests.

PLEASE NOTE THE FOLLOWING CLARIFICATIONS:

- 1) Please refer to SPECIAL PROVISIONS (SECTION 070) on page 070-1 for any requirements for Maintenance of Traffic (MOT). The costs for any and all MOT activities shall be included in the lump sum price for the project.

QUESTIONS FROM PROSPECTIVE BIDDERS

- Q. What are the rock specifications for crushed lime-rock?
- A. The crushed lime rock specified in the ITEM NOTES (SECTION 080) on page 080-1 of the bid documents has been changed as follows: crushed lime rock material is not required. The fill/embankment material shall meet a minimum LBR of 40. SBDD shall make a field determination on the suitability of the material. Any required material testing shall be paid for by SBDD and the Contractor shall be responsible to reimburse SBDD for the cost of any failed tests.

PLEASE NOTE THE FOLLOWING ADDITIONS/DELETIONS TO THE SCOPE OF WORK:

- 1) None